

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

Phone: 516-921-7100

Fax: 516-921-7920

REQUEST FOR INFORMATION

No. 00063

TITLE: Relocation of ALC TCP Panels

DATE: 6/15/2010

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Alan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:

COMPLETED:

REQUIRED: 6/22/2010

WORK

IMPACT: Unknown

SCHEDULE

IMPACT: Unknown

COST

IMPACT: Unknown

QUESTION:

6/15/10

Relocation of ALC TCP Panels

ICE would like permission to relocate two (2) of the ALC TCP Panels that are shown by the stairwell on the 2nd floor. The relocation requested would be as follows:

- 1) TCP for AHU-2 would be moved down to the Operating Floor level at Column Line 2 between E & F next to the Refrigerant Monitor Panel. Plans show this as clear space.
- 2) TCP for AHU-3 would be moved next to the Allen Bradley I/O Panel 600-2 on the Operating Floor. This is also shown on the plans as clear space.

Recommendation: ICE is recommending this change as it would locate the control panels closer to the equipment it controls. This would make startup and checkout easier and any future troubleshooting or maintenance would take less time.

CC: Bill Harrison, George Santorilla, File

PROPOSED SOLUTION:

THE PROPOSED TCP PANEL RELOCATION IS ACCEPTABLE -

W. HARRISON, GIFFELS 6-15-10

ANSWER:

Requested By: E.W. Howell Co., LLC

Date: _____

Signed: _____

Lauren Bergin